



अमरावती महानगरपालिका, अमरावती

अग्निशमन व आणीबाणी सेवा विभाग



अग्निशमन ना हरकत प्रमाणपत्र

प्रति, इंदिरा बहुउद्देशीय शिक्षण संस्था बिल्डिंग - 1
मार्डी रोड, अमरावती



नं. AMMC/FIRE-NOC/0169/23-24

कार्यालय अग्निशमन विभाग

ना.क्र.अ.म.न.पा/अग्नि.वि./0169/२०२४

दिनांक : 15/02/2024

संदर्भ :- (१) ना-हरकत मिळविण्याकरिता आपला प्राप्त अर्ज दि. 10/01/2024

(२) कोहिनूर सेफ्टी सर्विसेस, मुंबई या प्राधिकृत अभिकर्ता द्वारा प्राप्त फायर सेफ्टी ऑडिट रिपोर्ट दि. 25/09/2023

ना - हरकत प्रमाणपत्र

प्रमाणित करण्यात येते की, श्री / सौ. योगेश राजेंद्र गोडे

यांनी संदर्भ १ चे विनंती अर्जांनुसार व संदर्भ २ चे शासन प्राधिकृत अभिकर्ता / संस्थेद्वारे अग्निसुरक्षा ऑडिट करून Educational Insititte या व्यवसायासाठी अग्निशमन विभाग म.न.पा. अमरावती यांचे ना-हरकत प्रमाणपत्राची मागणी केली आहे. तसेच दि. 29/01/2024 ला तांत्रिक तपासणी अग्निशमन अधिकारी / प्राधिकृत अधिकारी यांनी केली. त्यानुसार खालील नियम व अटी शर्तीच्या आधीन राहून आपणास ना - हरकत प्रदान करण्यात येते.

- १) महाराष्ट्र आग प्रतिबंधक व जिवसंरक्षक अधिनियम २००६ चे भाग ४ व २००९ चे भाग ४ (ब) तसेच २००३ चे सुधारित अधिनियम अन्वये आपणास आगप्रतिबंधक उपाय योजना व यंत्रणा यामधीन तरतुदीचे अनुपालन करावे लागेल व NBC २०१६ मधील नियमांची पूर्तता करण्यात यावी तसेच महाराष्ट्र अग्निशमन सेवा संचालनालय व अमरावती महानगर पालिकेने वेळोवेळी सुधारणा केलेले नियम व त्यामधील बदल आपल्यावर बंधनकारक राहिल.
 - २) इमारतीचे Fire Safety Audit नुसार संपूर्ण अग्निसुरक्षा व्यवस्था करावी लागेल. आवश्यक त्या ठिकाणी धुम्रपान निषेध फलक लावावे लागेल व महत्वाचे दूर ध्वनी क्रमांक उदा, पोलिस नियंत्रण कक्ष अग्निशमन दल, ॲंब्युलन्स इ. चा फलक दर्शनिय ठिकाणी लावावे लागेल.
 - ३) अग्निसुरक्षा व्यवस्थेचे परिक्षण, मा. संचालक अग्निशमन सेवा, मुंबई यांनी नोंदणीकृत केलेले अनुज्ञाप्तीधारक अभिकरणांकडून जानेवारी व जुलै असे वर्षातून दोन वेळा अर्जदाराने स्वतःहून करून घेणे बंधनकारक राहिल.
 - ४) आपल्या सर्व कर्मचारी वर्गास अग्निरोधक उपकरणाची वेळोवेळी माहिती देण्यात यावी व सराव घेण्यात यावा.
 - ५) आग प्रतिबंधक उपाय योजना नेहमीसाठी कार्यान्वित रहावी याची दक्षता घ्यावी. सर्व विद्युत उपकरणे वेळोवेळी तांत्रिक तंत्रज्ञांकडून तपासून घ्यावेत.
 - ६) आग प्रतिबंधक उपाययोजना बाबत लावलेल्या अग्निशमन उपकरणाची पाहणी अग्निशमन दल मार्फत केव्हाही करण्यात येईल त्याकरिता आपली हरकत राहणार नाही. अग्निशमन ना-हरकतप्रमाणपत्र सोबत आवश्यक असल्यास इतर विभागाचे आवश्यक ते परवाने आपल्या स्तरावर प्राप्त करून घ्यावे.
 - ७) नाहरकत प्रमाणपत्राची वैधता १ वर्षाची राहिल.
 - ८) वरील अधिनियमाप्रमाणे व्यवस्थेअभावी आगीची कोणतीही घटना घडल्यास व त्यामध्ये जिवित व वित्त हानी झाल्यास त्याची सर्वस्वी जबाबदारी व्यवस्थापनाची (अर्जदार) यांची राहिल.
 - ९) दरवर्षी नियमानुसार नुतनीकरण शुल्क भरून अग्निशमन ना-हरकत प्रमाणपत्र प्राप्त करून घेणे अर्जदारास बंधनकारक राहिल.
 - १०) सदर अधिनियमामधील कोणत्याही तरतुदीन्वये काढलेल्या आदेशाची, नोटीसची किंवा निर्देशाचे उल्लंघन केले्यास किंवा अनुपालन करण्यात कसूर केले्यास संबंधित प्रकरणी अधिनियम मधील कलम ७, ८, ३६ नुसार कार्यवाही करण्यात येईल.
 - ११) अग्निशमन ना-हरकत प्रमाणपत्र हे केवळ अग्निशमन यंत्रणेकरिता मर्यादित राहिल याचा इमारत (निवासी, वाणिज्य) बांधकाम संदर्भात कुठलाही संबंध राहणार नाही.
 - १२) वरील बाबींची पूर्तता न झाल्यास आपले ना-हरकत प्रमाणपत्र रद्द समजण्यात येईल व याची सर्वस्वी जबाबदारी आपली राहिल.
- उपरोक्त प्रमाणपत्र हे दि. 14/02/2025 पर्यंत वैध राहिल
- टीप : १) अग्निशमन ना हरकत प्रमाणपत्राचे नुतनीकरण दरवर्षी करणे अनिवार्य आहे.
२) शासन नियमानुसार जानेवारी आणि जुलै महिन्यात फॉर्म बी सादर करणे अनिवार्य आहे

आयुक्त/उपायुक्त/मुख्य अग्निशमन अधिकारी/अग्नि अधिकारी

अमरावती महानगरपालिका, अमरावती

Amravati Municipal Corporation, Amravati
Fire and Emergency Service Department

Fire No Objection Certificate

No. AMMC/FIRE-NOC/0169/2024
Date: 15/02/2024

To,
Indira Bahaudeshiya Shikshan Sanstha,
Buldhana, Ghatkheda, Amravati.
O. no. A.M.C./F.D/222/2021
Campus Building-1.


References: 1. Your Application dated 10/01/2024 for the grant of No Objection Certificate.
2. Fire Safety Audit Report Dated 25/09/2023 received from authorized Inden Fire Protection Agency.

NO OBJECTION CERTIFICATE

It is to be certified that Shri./Principal Dr. Rajendra Gode Institute of Technology & Research, Amravati, have asked for the issuance of the no objection certificate in view of the request application in reference no. 1 and the fire safety audit report in reference no. 2 from authorized government agency/ institution for the Educational Business to the fire department, Amravati. Also, Fire & Safety Officer has completed technical inspection on 29/01/2024. Accordingly, no objection has been issued under the following Terms and Condition.

1. You should have to follow the provisions regarding the fire prevention plan and mechanism as provided under the Maharashtra Fire Prevention and Life Protection Act 2006-09 and has to comply with the NBC-2016 rules and similarly you are duty bound to all rules and changes incorporated by the state government and municipal corporation, Amravati.
2. The Fire Safety facility of building should have to be provided according to the Fire Safety Audit. Smoking Prohibited sign board have to be affix at require places and sign board showing the important telephone no. like Police Control Room, Fire Brigade, Ambulance etc. have to be affix at visible places.
3. It is binding to get inspection of fire safety facilities from the authorized agency registered with the Hon'ble Director Fire Service, Mumbai two times within the year between the periods of January to July.
4. All your employees should get inform time to time about the fire prevention equipment and through demonstration etc.
5. All electrical equipment should be checked by the sure agent to ensure that fire prevention plans are always implemented.

Notary



6. Fire equipment installed in the fire prevention scheme will be inspected by the fire brigade at any time. Fire no objection certificate along with the necessary licenses of other departments should have to be provided.

7. The validity of No Objection Certificate is for 1 year.

8. In case of happening any fire accident due to non-availability of facility as mentioned above the whole responsibility of the same will be on the administration (applicant).

9. It is binding to get renewal of the no objection certificate every year by depositing the renewal charges.


10. In case of infringement of this act or rules made under it of in case of violation of to know any order or any notice or any other directive issued under the provision of this Act or any rules made thereunder shall be liable for any action as per section 7,8,36. of this

11. In case of failure to comply above said terms and condition resulted into termination of the no objection certificate and whole responsibility of the same is remaining upon you.

This certificate is valid till dated 14/02/2025.

Note:

1. It is compulsory to renew the fir No Objection Certificate every year.
2. It compulsory to present Form B Certificate within every six months as per Governments Rules.



Sd/-

Commissioner / Dy Commissioner / Fire Superintendent
Amravati Municipal Corporation, Amravati.

Notary

Sagar Chandrakant Jirapure
Digitally signed by Sagar Chandrakant Jirapure
Date: 2024.12.06 17:45:28 +05'30'



TRUE TRANSLATION

ATTESTED BY ME

Ambarish Pralhadrao Deshmukh
ADVOCATE & NOTARY
"Ambarish", Infront of
Police Commissioner Bungalows,
Mr. Reserve Police Line Camp,
Amravati, M.G.-444 602.
Reg. No. 11218





KOHINOOR SAFETY SERVICES

AN ISO 9001: 2015 Certified Company

📍 Head Office: Shop no 1, Swami Narayan Nagar, Kailash Complex, Tata Power, Powai - 4000 76.

📍 Branches: Kandivali | Andheri | Bhandup.

☎ +91 98926 13864, +91 95949 67751 🌐 www.kohinoorsafetyservices.in, www.extinguishers.in

✉ fire.india@yahoo.com, info@kohinoorsafetyservices.in, kohinoorsafetyservices@gmail.com

FIRE-SAFETY AUDIT REPORT

PROJECT NAME: - "Indira Bahuuddeshiya Shikashan Sanstha", Amravati Campus
- Bldg. No.: -01"

PROJECT LOCATION: - 'Bldg.-01, Indira Bahuuddeshiya Shikashan Sanstha, Amravati
Campus, Mardi Road, Amravati (MH) - 444 602.

1. Name & Address of the building: 'Bldg.-01, Indira Bahuuddeshiya Shikashan Sanstha, Amravati Campus, Mardi Road, Amravati (MH) - 444 602.
2. Type of Occupancy : - COLLEGE - EDUCATIONAL - B
3. Use of the building : - COLLEGE - EDUCATIONAL - B
4. Fire Safety directives letter No. : - NA
5. Date of inspection : - 25.09.2023
6. Name of the inspecting Officer / Agency : - Mr. Ujjwal Narkhede
: - Fire Safety Auditor Certificate No.: 225230331
7. Name & Designation of Office : - Mr. Dr. A.V. Parwate
if any, representing the owner/ : - PRINCIPAL
Occupier of the building. : - M.: +91- 7402414100
8. Year of construction of building: -
9. Total Built-up area of Building : - 6818.35 SQ. FEET
10. Max. Height of the Building : - 14.750 Mtrs. (As per drawing)
11. Total Number of Floors : - Gr. + 02 floor

**KARTAR
SUGRIV
CHAUHAN** Digitally signed by
KARTAR SUGRIV
CHAUHAN
Date: 2023.11.07
15:42:18 +05'30'



KOHINOOR SAFETY SERVICES

AN ISO 9001: 2015 Certified Company

📍 **Head Office:** Shop no 1, Swami Narayan Nagar, Kailash Complex, Tata Power, Powai - 4000 76.

📍 **Branches:** Kandivali | Andheri | Bhandup.

☎ +91 98926 13864, +91 95949 67751 🌐 www.kohinoorsafety.com, www.extinguishers.in

✉ fire.india@yahoo.com, info@kohinoorsafety.com, kohinoorsafety@gmail.com

Sr. No.	Minimum Standards for the Fire Prevention and Fire Safety	Requirement as per NBC 2016	Provided at site	Remarks (Meets/ Doesn't meet requirements)
1.	Access to the building <ul style="list-style-type: none"> - Road width - Gate width - Width of internal road 	5.0 m 3 m NA	7.50 Mtr 3 m 7.50 Mtr	Meet requirement Meet requirement Meet requirement
2.	Means of egress <ul style="list-style-type: none"> a. Number of staircases <ul style="list-style-type: none"> - Upper floors. - Basements. b. Width of staircases <ul style="list-style-type: none"> - Upper Floors. - Basements. c. Protection of exits <ul style="list-style-type: none"> - Fire Check door - Pressurization d. No. of continuous staircases to terrace e. Staircase lobby f. Width of Corridor g. Door Size 	01 Nos - 1.2 m NA NA NA 01 No's 2.0 m 2.0 m NA	02 No's - 1.6 m NA NA NA 01 No's 2.50 m 2.50 m NA	Meet requirement Meet requirement Meet requirement Meet requirement NA NA Meet requirement Meet requirement Meet requirement NA
3.	Compartmentation <ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shafts door • Size of compartment • Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	Smoke Management System <ul style="list-style-type: none"> • Basement • Upper floors 	NA Required	NA Provided	NA Meet requirements
5.	Fire Extinguishers <ul style="list-style-type: none"> - Total Numbers - Types - ISI Marking 	ABC-04Kg. / ABC-06Kg. / CO2-4.5Kg. ISI Marked	Provided 31 Nos 29No's 02No's ISI:15683	Meet requirements Meet requirements Meet requirements Meet requirements Meet requirements
6.	First Aid Hose Reel <ul style="list-style-type: none"> - Total No's on each floor - Length of Hose Reel - Nozzle diameter 	Required 01 No's 30 Mtr 15 mm Dia.	Provided 01 No's Provided Provided	Meet requirements Meet requirements Meet requirements Meet requirements

Digitally signed by
KARTAR SUGRIV CHAUHAN
 Date: 2023.11.07 15:30:05
 +05'30'



KOHINOOR SAFETY SERVICES

AN ISO 9001: 2015 Certified Company

📍 Head Office: Shop no 1, Swami Narayan Nagar, Kailash Complex, Tata Power, Powai - 4000 76.

📍 Branches: Kandivali | Andheri | Bhandup.

☎ +91 98926 13864, +91 95949 67751 🌐 www.kohinoorsafetyservices.in, www.extinguishers.in

✉ fire.india@yahoo.com, info@kohinoorsafetyservices.in, kohinoorsafetyservices@gmail.com

14.	Captive Water Storage for Fire Fighting - Underground tank capacity ✓ Draw – off connection ✓ Fire service inlet ✓ Access to tank - Overhead tank capacity	NA NA Required NA Required	NA NA Provided NA 10,000 lit	N.A. NA Meet requirement NA Meet requirement
15.	Exit Signage	Required	Provided	Meet requirement
16.	Provision of lifts - Pressurization of lift shaft - Pressurization of lift Lobby - Communication facility in lift - Fireman’s Grounding Switch - Lift Signage	N.A. N.A. N.A. N.A. N.A. N.A.	N.A. N.A. N.A. N.A. N.A. N.A.	N.A. N.A. N.A. N.A. N.A. N.A.
17.	Stand by power supply	Required	Provided	Meet requirement
18.	Refuge Area ✓ Total area ✓ Location	NA NA NA	NA NA NA	NA NA NA
19.	Fire Control Room • Control Panel ✓ Detector system ✓ Flow Switch Panel ✓ PA system panel ✓ Batter backup if any ✓ Building floor plans	NA NA NA NA NA NA NA	NA NA NA NA NA NA NA	NA NA NA NA NA NA NA
20.	Special Fire Protection System For Protection of Special Risks	NA	NA	NA

The fire protection equipment mentioned (if any) above is provided at the time of inspection of the building / premises. Considering the limits of compliance with the minimum standards of fire prevention and fire safety required by the rules, it is proposed as follows. –

1. Down-Comer Fire Hydrant should be provided.
2. Fire brigade Inlet Breaching should be provided for Each Down-Comer.
3. 450LPM Booster Pump should be provided.
4. Overhead Water Tank (Concrete) of Capacity: 10,000 Ltrs. should be provided.
 1. Need to maintain all electrical appliances, cables, etc., in safe condition
 2. Need to adhere this audit and required to provide mention requirements.

**KARTAR
SUGRIV
CHAUHAN**

Digitally signed by
KARTAR SUGRIV
CHAUHAN
Date: 2023.11.07
15:43:02 +05'30'



KOHINOOR SAFETY SERVICES

AN ISO 9001: 2015 Certified Company

📍 **Head Office:** Shop no 1, Swami Narayan Nagar, Kailash Complex, Tata Power, Powai - 4000 76.
📍 **Branches:** Kandivali | Andheri | Bhandup.
📞 +91 98926 13864, +91 95949 67751 🌐 www.kohinoorsafetyservices.in, www.extinguishers.in
✉️ fire.india@yahoo.com, info@kohinoorsafetyservices.in, kohinoorsafetyservices@gmail.com

MEETS at Building

1. Fire Hydrant Down-Comer with First Aid Fire Hose Reel system is provided at site/Building.
2. Fire Brigade Inlet Breaching is found at Main Entrance.
3. 450LPM Booster Pump is Provided at terrace with overhead water tank capacity of 10,000 Ltrs.
4. Fire Extinguishers of appropriate type & Quantity is found in working conditions.

Place: Amravati

Date: 25/09/2023

**KARTAR
SUGRIV
CHAUHAN** Digitally signed by
KARTAR SUGRIV
CHAUHAN
Date: 2023.11.07
15:43:14 +05'30'

Signature

**Sagar
Chandra
kant
Jirapure** Digitally signed
by Sagar
Chandrakant
Jirapure
Date:
2024.12.06
12:17:52 +05'30'